



Addendum No: 01

IFB # 25 - 015

Roof Replacement Service

Questions and Answers

Question 1: what size insulation will be required to be put back?

Answer: This will be by Core Samples. Replacing with like material.

Question 2: What will need to be done about the lighting protection?

Answer: The contractor will be responsible for removing and reinstalling the existing rod. The contractor is also responsible for obtaining re- certification.

NOTE: 1. Vendors must provide two quotes. One with installation and one without installation.

2. ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED