



## Invitation to Bid (ITB) Addendum

**IFB No.** 26-050 **Addendum One (1)**  
**IFB Title** Electric Vehicle Charging Stations

---

**February 25, 2026**

**To: All Bidders,**

This addendum includes the following additions, clarifications, and/or modifications and shall become a part of the plans and specifications. This addendum shall supersede the original bid documents in the event of any conflict.

I. The Bid Due Date has been revised. Sealed bids for the above-referenced project will now be received until **March 4, 2026 by 2:00 pm local time.**

II. Questions and Answers:

1) Q: Does GoTriangle have all the ChargePoint equipment?

A: All equipment is on site except for two Surface Conduit Entry Kits for the Power Blocks. The two kits have been ordered by GoTriangle and ChargePoint expects to deliver before award.

Also, see answer to question three (3) below.

2) Q: Are the ChargePoint chargers on site?

A: See answer to question one (1) above.

3) Q: Does GoTriangle intend to provide the precast pads?

A: Please see bid item 5 & 7 – POWER LINK PRECAST PAD qt four (4) each and CPE250 SINGLE PRECAST PAD qt four (4) each on the bid form. Bidders are to provide all materials, labor, and equipment for these items.

4) Q: Designs are conflicting with 1000 amp or 800 amp. Please define.

A: See the load table on sheet 6, showing required amps and note the language regarding the use of load management software: **LOAD MANAGEMENT SHALL BE IMPLEMENTED TO OPERATE WITHIN AVAILABLE AMPACITY.** It is the intent to retain the existing panel.

5) Q: Will there be any striping involved?

A: If any damage to markings or other existing infrastructure occurs due to installation of the charging equipment, the contractor shall make these repairs. No additional compensation will be paid for these repairs.

6) Q: Can the time for project completion be increased?

A: Yes, time to complete the project from the time of award has been increased to a total of 150 days.

7) Q: What kind of bollards are required?

A: Along with the bollard detail on sheet 5 of the plans, use a minimum thickness of ¼”.

III. Pre bid meeting attendees listed attached

ALL OTHER TERMS, CONDITIONS, AND REQUIREMENTS REMAIN IN FULL FORCE AND EFFECT.



# Pre-Bid Conference Sign-in Sheet

2/18/2026

Invitation For Bid number 26-050  
Electric Vehicle Charging Stations

	Company	Name	Email	Telephone
1	GoTriangle	Dean Nunnally	Dnunnally@gotriangle.org	(919) 314-8768
2	GoTriangle	Jimmy Price	Jprice@gotriangle.org	(919) 314-8768
3	GoTriangle	Willie Reid	Wreid@gotriangle.org	(919) 314-8768
4	GoTriangle	Purshotam Khemraj	Pkhemraj@gotriangle.org	(919) 314-8768
5	GoTriangle	Vinson Hines	Vhines@gotriangle.org	(919) 314-8768
6	GoTriangle	Bryan Hammond	Bhammond@gotriangle.org	(919) 314-8768
7	GoTriangle	Darric Harris	Dharris@gotriangle.org	(919) 314-8768
8	Spatco	Joel T. Bulpitt	Joel.bulpit@spatco.com	(919) 896-4305
9	STV	John Johnson	John.johnson@stvinc.com	(704) 288-7391
10	BRC	Terry Bryant	Tbry@brcpm.com	(919) 200-8904
11	RDA	Alan Watts	Alan@rdasolar.com	(919) 368-7593
12	Tayco Electric	Whitney Smith and Chris Castano	Whitney@taycoelectric.com	(843) 270-7773

Bidders must acknowledge receipt of this addendum by signing in the space provided below and returning the Addendum with your bid package.

**Sign below and return this addendum with your bid**

---

**Bidder's Company Name:** \_\_\_\_\_ **Date:** \_\_\_\_\_

**Signature:** \_\_\_\_\_ **Title:** \_\_\_\_\_